



MATERIALS

ITEM	QUANT.	DESCRIPTION
1	2	2" BACKFLOW PREVENTER
2	18	2" NIPPLES
2A	2	2" X NOM. NIPPLES
3	2	2" COUPLING - COMPRESSION
4	4	2" X 90° ELBOW
5	4	2" GATE VALVE
6	2	2" TEE
7		PEA GRAVEL
8		FILTER FABRIC
9	2	2" WYE STRAINER

- NOTES: 1. INSTALLATION SHOWN ABOVE IS FOR A 2" SERVICE. CHANGE PIPING MATERIALS ACCORDINGLY FOR SERVICE SIZE.
 2. CUT ENDS OF ITEM 2A IN THE FIELD.
 3. TEST COCK ON VALVE FOR DOUBLE CHECK.
 4. USE COPPER, BRASS OR STAINLESS STEEL FOR FITTINGS AND PIPE MATERIAL.

